

Objects In Graphics

S1-ADS1:S1-ADS1/Graphics.Air Systems.AHU-1

File Name: S1-ADS1:S1-ADS1/Graphics.Air Systems.AHU-1

Last Upload:

Last Compile:

Object Name	Description	Reference	ObjectClass
GSA Courthouse.S1-NAE1-T1-FEC12 (CHW SYS).OA-T	Outdoor Air Temperature	S1-ADS1:S1-NAE1/FC-1.CHW SYS.OA-T	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).CLG-EN	Cooling Is Available	S1-ADS1:S1-NAE1/FC-1.AHU-1.CLG-EN	BV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).CLG-O	Cooling Output	S1-ADS1:S1-NAE1/FC-1.AHU-1.CLG-O	AO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).CLGUNOCC-SP	Night Cooling Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.CLGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DA-H	Discharge Air Humidity	S1-ADS1:S1-NAE1/FC-1.AHU-1.DA-H	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DA-P	Discharge Air Static Pressure	S1-ADS1:S1-NAE1/FC-1.AHU-1.DA-P	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DAP-SP	Duct Static Pressure Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.DAP-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DA-T	Discharge Air Temperature	S1-ADS1:S1-NAE1/FC-1.AHU-1.DA-T	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DATCLGUNOCC-SP	Unocc Cooling Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.DATCLGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DATHTGUNOCC-SP	Unocc Heating Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.DATHTGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).DAT-SP	Discharge Air Temperature Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.DAT-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).ECON-EN	Economizer Is Available	S1-ADS1:S1-NAE1/FC-1.AHU-1.ECON-EN	BV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).EF2-S	Exhaust Fan 2 Status	S1-ADS1:S1-NAE1/FC-1.AHU-1.EF2-S	BI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).HTGUNOCC-SP	Night Heating Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.HTGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).HUM-A	Humidifier Alarm	S1-ADS1:S1-NAE1/FC-1.AHU-1.HUM-A	BI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).HUM-EN	Humidification Is Available	S1-ADS1:S1-NAE1/FC-1.AHU-1.HUM-EN	BV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).HUM-O	Humidifier Output	S1-ADS1:S1-NAE1/FC-1.AHU-1.HUM-O	AO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).HUM-SP	Return Air Humidity Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.HUM-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MAD-O	Mixed Air Damper Output	S1-ADS1:S1-NAE1/FC-1.AHU-1.MAD-O	AO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MA-T	Mixed Air Temperature	S1-ADS1:S1-NAE1/FC-1.AHU-1.MA-T	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MOA-CO2RSTH	CO2 Reset Low Limit	S1-ADS1:S1-NAE1/FC-1.AHU-1.MOA-CO2RSTH	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MOA-CO2RSTL	CO2 Reset High Limit	S1-ADS1:S1-NAE1/FC-1.AHU-1.MOA-CO2RSTL	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MOA-MAXPOS	OA Damper High CO2 Position	S1-ADS1:S1-NAE1/FC-1.AHU-1.MOA-MAXPOS	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MOA-MINPOS	OA Damper Low CO2 Position	S1-ADS1:S1-NAE1/FC-1.AHU-1.MOA-MINPOS	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MPHD-C	Minimum Preheat Damper Command	S1-ADS1:S1-NAE1/FC-1.AHU-1.MPHD-C	BO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).MPH-O	Minimum Preheat Output	S1-ADS1:S1-NAE1/FC-1.AHU-1.MPH-O	AO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).OCC-SCHEDULE	Occupancy Schedule	S1-ADS1:S1-NAE1/FC-1.AHU-1.OCC-SCHEDULE	MSV Mapper

GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).PH-SP	Minimum Preheat Damper OA Setpoint	S1-ADS1:S1-NAE1/FC-1.AHU-1.PH-SP	AV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).PH-T	Preheat Temperature	S1-ADS1:S1-NAE1/FC-1.AHU-1.PH-T	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).RA-H	Return Air Humidity	S1-ADS1:S1-NAE1/FC-1.AHU-1.RA-H	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).RA-Q	Return Air Quality	S1-ADS1:S1-NAE1/FC-1.AHU-1.RA-Q	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).RA-T	Return Air Temperature	S1-ADS1:S1-NAE1/FC-1.AHU-1.RA-T	AI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).SAFETY-A	Low Temp or High Static Alarm	S1-ADS1:S1-NAE1/FC-1.AHU-1.SAFETY-A	BI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).SF-C	Supply Fan Command	S1-ADS1:S1-NAE1/FC-1.AHU-1.SF-C	BO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).SF-O	Supply Fan Output	S1-ADS1:S1-NAE1/FC-1.AHU-1.SF-O	AO Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).SF-S	Supply Fan Status	S1-ADS1:S1-NAE1/FC-1.AHU-1.SF-S	BI Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).SF-S.Present Value		S1-ADS1:S1-NAE1/FC-1.AHU-1.SF-S.Alarm1	Multistate Alarm
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).WC-C	Warmup Cooldown Mode	S1-ADS1:S1-NAE1/FC-1.AHU-1.WC-C	MSV Mapper
GSA Courthouse.S1-NAE1-T1-FEC4 (AHU-1).ZN-T	Average Zone Temperature	S1-ADS1:S1-NAE1/FC-1.AHU-1.ZN-T	AV Mapper
Legend		S1-ADS1:S1-ADS1/Graphics.Legend	Graphic
Main		S1-ADS1:S1-ADS1/Graphics.Main	Graphic

S1-ADS1:S1-ADS1/Graphics.Air Systems.AHU-11

File Name: S1-ADS1:S1-ADS1/Graphics.Air Systems.AHU-11

Last Upload:

Last Compile:

Object Name	Description	Reference	ObjectClass
GSA Courthouse.S1-NAE1-T1-FEC12 (CHW SYS).OA-T	Outdoor Air Temperature	S1-ADS1:S1-NAE1/FC-1.CHW SYS.OA-T	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).BLDG-P	Building Static Pressure	S1-ADS1:S1-NAE1/FC-2.AHU-11.BLDG-P	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).BLDGP-SP	Building Static Pressure Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.BLDGP-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).CLG-EN	Cooling isAvailable	S1-ADS1:S1-NAE1/FC-2.AHU-11.CLG-EN	BV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).CLG-O	Cooling Output	S1-ADS1:S1-NAE1/FC-2.AHU-11.CLG-O	AO Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).CLGUNOCC-SP	Night Cooling Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.CLGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DA1-P	Discharge Air Static Pressure 1	S1-ADS1:S1-NAE1/FC-2.AHU-11.DA1-P	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DA2-P	Discharge Air Static Pressure 2	S1-ADS1:S1-NAE1/FC-2.AHU-11.DA2-P	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DA-H	Discharge Air Humidity	S1-ADS1:S1-NAE1/FC-2.AHU-11.DA-H	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DAP-LL	Duct Static Pressure Low Limit	S1-ADS1:S1-NAE1/FC-2.AHU-11.DAP-LL	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DAP-SP	Duct Static Pressure Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.DAP-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DA-T	Discharge Air Temperature	S1-ADS1:S1-NAE1/FC-2.AHU-11.DA-T	AI Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DATCLGUNOCC-SP	Unocc Cooling Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.DATCLGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DATHTGUNOCC-SP	Unocc Heating Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.DATHTGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).DAT-SP	Discharge Air Temperature Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.DAT-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).ECON-EN	Economizer Is Available	S1-ADS1:S1-NAE1/FC-2.AHU-11.ECON-EN	BV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).HTGUNOCC-SP	Night Heating Setpoint	S1-ADS1:S1-NAE1/FC-2.AHU-11.HTGUNOCC-SP	AV Mapper
GSA Courthouse.S1-NAE1-T2-FEC7 (AHU-11).HUM-A	Humidifier Alarm	S1-ADS1:S1-NAE1/FC-2.AHU-11.HUM-A	BI Mapper